## CERTIFICATE OF COMPLIANCE

Certificate Number 20170207-E125326

Report Reference E125326-20010817

Issue Date 2017-FEBRUARY-07

Issued to: Topworx Inc

3300 Fern Valley Rd

Louisville, KY 40213-3528 USA

This is to certify that Telem

Telemetering Equipment for Use in Hazardous Locations

representative samples of (See following page for additional information.)

Have been investigated by UL in accordance with the

Standard(s) indicated on this Certificate.

Standard(s) for Safety: ANSI/ISA-12.12.01-2011, Nonincendive Electrical

Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations, 2011 Edition Approved 2011-08-24, UL 1203, Third Edition, and

UL 508, Seventeenth Edition.

CSA C22.2 No. 30-M1986, C22.2 No. 213-M1987 and

C22.2 No. 14-92.

Additional Information: See the UL Online Certifications Directory at

www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC





## CERTIFICATE OF COMPLIANCE

Certificate Number 20170207-E125326

Report Reference E125326-20010817

Issue Date 2017-FEBRUARY-07

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

## Additional Information:

USL, CNL Class I, Division 2, Groups A, B, C and D; Class II, Division 2, Groups F and G, Hazardous Locations.

Discrete Valve Controller DVC or DVM followed by MB or DN, followed by Z2, followed by B or N, followed by P, followed by one to three alphanumeric character designators.

Valve Controller/Monitor, Model DXR-, followed by MB or DN, followed by 2, followed by any number or letter, followed by S, N, 1 or 2, followed by E, 4, M, 5, 8, 6, 1, 9, or 7, followed by O, B, V, E, or S, followed by Blank, 1, 2, or 3, followed by Blank, A, S, 6, B or R, followed by any number or letter, followed by any number or letter.

USL, CNL Class I, Division 1, Groups C and D, Class I, Division 2, Groups A, B, C and D Hazardous Locations.

Valve Controller/Monitor, Model DXS/DXP-, followed by MB or DN, followed by 1 or 2, followed by any number or letter, followed by S, N, 1 or 2, followed by E, 4, M, 5, 8, 6, 1, 9, or 7, followed by O, B, V, E, or S, followed by Blank, 1, 2, or 3, followed by Blank, A, S, 6, B or R, followed by any number or letter, followed by any number or letter.



Bruce Mahrenholz, Director North American Certification Program

UL LLC



