

Introduction:

This guide outlines a quick and easy 3-step method for precision shaft alignment.


Set-up:

Choose the shortest support posts that will still allow the laser beam to pass over or through the coupling. Mount the laser fixtures by sliding each head over the support posts and locking them into place with the yellow clamping levers.

Mount laser heads as shown above, being careful to mount the laser on the stationary machine.

Sweep Size:

The "Auto Sweep" method provides a simple, accurate solution for any alignment task. Start anywhere. Stop anywhere. While it is always best to completely rotate the shaft, this method can be used effectively with partial sweeps down to 45°. Press [ENTER] to retrieve data via Bluetooth.




Optional – Job Storage

Alignment jobs can also be saved and printed.

This is found under "Job Manager" on the ALT screen of the main menu.

	* Edit Job Setup		Set
	Location: Internal	Mode: Horizontal	Mode
Edit Job ID	Job ID: FEED PUMP	User ID: RDS	Edit User ID
Edit Equip ID	Equipment: FP 12		
Edit Equip Desc	Equipment Descriptio COLD WATER PUMP	n:	
Edit Area	Area: POWER HOUSE		
Edit Coupling Number	Coupling Number: 1		

Refer to the user manual to learn how to upload saved jobs back to the PC software.



You can customize the machine graphics using a selection of different machine types. Consult the user manual for additional details, advanced functions, and instructions.

Operating Notes:

Laser fixtures are for shaft alignment only and should be operated by properly trained personnel. As precision instruments, care should be taken to not subject them to shock.

Laser Safety:

- Do not stare directly into the laser beam!
 [NOTE: Red LED on Laser Head indicates that laser is active.]
- Do not insert optical devices into beam.





P/N: MHM-97109, rev 1




AMS 2140 Machinery Health™ Analyzer

Pocket Guide For Laser Shaft Alignment



EMERSON, CONSIDER IT SOLVED

1 Enter Dimensions




Values for A, B, E and RPM are required. Use [<] and [>] to move between fields.



Optional machines types enable entry of values for C and D for the other machine. Note: Use [./] to calculate fractions. Example: 30 3/8 = [3] [0] [./] [3] [./] [./] [8]


Optional: Foot Pre-Check


To check foot condition, press [F12] before sweeping laser fixtures and follow on-screen instructions. Use a feeler gauge to determine required shim correction. The Soft Foot option provides you with a sense of severity without showing numbers. The FDI option will provide an estimate of the required shim.



OK = Good XX = Bad X = Soft XXX = Extreme

2 Sweep Laser Heads






Sweep laser heads. Start anywhere. Stop anywhere. Minimum recommended sweep size is 45°. Press [ENTER] to retrieve data via Bluetooth.

Bluetooth Set-Up


- 1. Press [Home] > [F5] Comm Setup > [F7] Bluetooth Setup.
- Press [F2] Bluetooth to enable or disable the Bluetooth radio. When the radio is enabled, the Bluetooth LED on the top of the analyzer turns on and the icon appears in the upper corner of the screen.
- 3. Press [F7] Pair to pair the sensor.

 "Paired" appears next to the device once the laser heads are connected to the analyzer. To differentiate between laser heads and headphones, a laser image as shown to the right is displayed next to the serial number.

3 Move Machine



The Vertical
Machine Move
indicates how much
to shim/drop each
machine foot.



When viewing the Horizontal Move screen, press [F12] for 'LIVE MOVE'. Place laser fixtures in desired position and press [ENTER] to start.

Shaft Alignment Indicator

The bull's eye display continuously updates alignment status.

Display	Meaning	
0	Way out. More than 2x tolerance.	
0	Getting close. 1-2x tolerance.	
	Good job! Below acceptable tolerance.	
	Great job! Below excellent tolerance.	

Emerson Reliability Solutions

835 Innovation Drive Knoxville, TN 37932 USA • +1 865 675 2400

www.emerson.com/ams