

防爆合格证

Electrical Apparatus for Explosive Atmospheres

CERTIFICATE OF CONFORMITY

Manufacturer

Topworx Incorporated

3300 Fern Valley Road, Louisville, Kentucky, 40213, United States of America

Product

国家防爆

Switchboxes

Type

DX*-*1/C ***********

Marking

Ex d IIC T3/T4/T5/T6 Gb , Ex d IIB+ H_2 T3/T4/T5/T6 Gb ,

Ex tD A21 IP66/67 T85 ℃/T100 ℃/T135 ℃

Standard(s)

--

Drawing No.

ES-01141-1

The drawings, technical documents and the samples are verified and certified according to standard(s) for safety as below:

GB 3836.1-2010

Explosive atmospheres - Part 1: Equipment - General requirements

GB 3836.2-2014

Explosive atmospheres - Part 2: Equipment protection by flameproof enclosure "d"

GB12476.1-2013

Electrical apparatus for use in the presence of combustible dust - Part 1:General

requirements

GB12476.5-2013

Electrical apparatus for use in the presence of combustible dust - Part

5:Protection by enclosure "tD"

Note:

See Annex (4 pages in total).

Director

1/2

Date:

Valid until:





南阳防爆电气研究所

NANYANG EXPLOSION PROTECTED ELECTRICAL APPARATUS RESEARCH INSTITUTE

国家防爆电气产品质量检验检测中心

CHINA NATIONAL QUALITY SURVEY AND TEST SENTEN FOR EXPLOSION PROTECTED ELECTRICAL PRODUCTS
Address No.2000 of The State of Telegraph (1998), P.R.China
Tel:037 6325854 Fax:0377 63208175 Web. wow.china-ex.com



Electrical Apparatus for Explosive Atmospheres

CERTIFICATE OF CONFORMITY

Page 1 of 4

1.This product has been certified, under certificate number IECEx SIR 07.0093X, issue 15, dated 2021-07-08.

2.Type designation:

国家防爆

DX*-*1/C *******

5X - 1/C														
DX	*	-	*	1/C	*	*	*	*	*	*	*	*	*	*****
1)	2)		3)	4)	5)	6)	7)	8)	9)	10)	11)	12)	13)	14)

- 1) Enclosure
- 2) Enclosure Material P=Aluminum S=316SS
- 3) Bus/Sensor

A0 = AS-i (no switches)

AS = AS-I w/(2) SPDT GO Switches

B1, B2, B3, B4 = P+F NJ2-12GK-SN

D0 = Devicenet (no switches)

DN = Devicenet w/(2) SPDT GO Switches

E1, E2, E3, E4, E5, E6 = P+F NJ2-V3-N

EX = (2) P+F NJ2-V3-N w/4-20mA Transmitter

EH = (2) P+F NJ2-V3-N w/HART Transmitter

ES = Emergency Shutdown Device w/(2) SPDT GO Switches

F1, F2 = P+F NJ2-12GK-N

FF = Foundation Fieldbus w/0-10k Potentiometer

FL = Foundation Fieldbus w/(2) GO Switches

FP = Foundation Fieldbus w/(2) GO Switches & 0-10k Potentiometer

J1, J2 = P+F NJ2-11-SN-G

K1, K2, K3, K4, K5, K6 = MECH SWITCH SPDT w/GOLD CONTACTS

KX = (2) MECH SWITCH SPDT w/4-20mA Transmitter

KH or HK = (2) MECH SWITCH SPDT w/HART Transmitter

L1, L2, L3, L4 = GO SWITCH SPDT

LX = (2) GO SWITCH SPDT w/4-20mA Transmitter

LH or HL = (2) GO SWITCH SPDT w/HART Transmitter

Director

Date:

2022-03-07

Valid until:

2027-03-06





NANYANG EXPLOSION PROTECTED ELECTRICAL APPARATUS RESEARCH INSTITUTE

国家防爆电气产品质量检验检测中心

CHINA NATIONAL QUALITY SURVEY AND TEST CENTER FOR EXPLOSION PROTECTED ELECTRICAL PRODUCTS
Address No. 20 Godt Zhongjing Rd, Nanyang Hanan (473008), P.R. China
Tel: 0371 63258564 Fax: 0377 63208175 Web: www.china-ex.com

注: 本证书仅对与认可文件和样品一致的产品有效。

登录网站或关注公众号查询真伪



Electrical Apparatus for Explosive Atmospheres

CERTIFICATE OF CONFORMITY

Page 2 of 4

M1, M2, M3, M4, M5, M6 = MECH SWITCH SPDT

MX = (2) MECH SWITCH SPDT w/4-20mA Transmitter

MH or HM = (2) MECH SWITCH SPDT w/HART Transmitter

N1, N2, N3, N4, N5, N6 = ANY NAMUR SWITCH

NX = (2) ANY NAMUR SWITCH w/4-20mA Transmitter

NH = (2) ANY NAMUR SWITCH w/HART Transmitter

PO = Profibus (no switches)

PB = PROFIBUS w/(2) SPDT GO Switches

T2 = MECH SWITCH DPDT

TX = MECH SWITCH DPDT w/4-20mA Transmitter

V1, V2, V3, V4 = P+F NJ3-18GK-S1N

Z1, Z2, Z3, Z4 = GO SWITCH DPDT

ZX = (2) GO SWITCH DPDT w/4-20mA Transmitter

ZH = (2) GO SWITCH DPDT w/HART Transmitter

00 = NO SWITCH

31, 32, 33, 34 = P+F NJ5-30GK-S1N

41, 42, 43, 44 = P+F NBB2-V3-E2

51, 52, 53, 54 = P+F NBB3-V3-Z4

61, 62, 63, 64 = P+F NBB4-12GM40-Z0

71, 72, 73, 74 = P+F NJ2-12GM40-E2

81, 82, 83, 84 = ITW MECH SWITCH DPDT

4) Area Class

国家防爆

1=IIB+H₂, C=IIC

5) Visual Display:

ANY NUMBER OR LETTER

6) Shaft:

ANY NUMBER OR LETTER

7) Conduit Entries:

ANY NUMBER OR LETTER

Director

94

Date:

Valid until:





南阳防爆电气研究所

NANYANG EXPLOSION PROTECTED ELECTRICAL APPARATUS RESEARCH INSTITUTE

国家防爆电气产品质量检验检测中心

CHINA NATIONAL QUALITY SURVEY AND TEST CENTEN FOR EXPLOSION PROTECTED ELECTRICAL PRODUCTS
Address No. 20 Morth Zhongjing Rd, Nanyang Hanan (47308), P.R.China
Tel:037 6329864 Fax:0377 63208175 Webywyw.china-ex.com



Electrical Apparatus for Explosive Atmospheres

CERTIFICATE OF CONFORMITY

Page 3 of 4

8) O-Rings:

国家防爆

B=BUNA

E=EPDM

S=SOLICONE

V=VITON

9) Pilot

0 or Blank = No Pilot

1=24VDC FAIL Open/Closed

2=24VDC FAIL Last Position

4=220VAC FAIL Open/Closed

5=220VAC FAIL Last Position

7=110VAC FAIL Open/Closed

8=110VAC FAIL Last Position

P=PIEZO FAIL Open/Closed

R=PIEZO FAIL Last Position

10) Spool

ANY NUMBER OR LETTER OR BLANK

11) Valve Cv:

ANY NUMBER OR LETTER OR BLANK

12) Override:

ANY NUMBER OR LETTER OR BLANK

13) Regional Certs:

0 or BLANK = UL (North America), IECEx, ATEX

B = InMetro (Brazil)

K = KCs (Korea)

N = CCCEx (China)

P = PESO (India)

R = EAC (Eurasian Economic Union)

T = ITRI (China Taiwan)

14) Custom Build Indents

6 digits (without relevance for explosion protection)

Director

引星

Date:

Valid until:





南阳防爆电气研究所

NANYANG EXPLOSION PROTECTED ELECTRICAL APPARATUS RESEARCH INSTITUTE

国家防爆电气产品质量检验检测中心

CHINA NATIONAL QUALITY SURVEY AND TEST CENTER FOR EXPLOSION PROTECTED ELECTRICAL PRODUCTS
Address No. 20 00 dts Zhongjing Rd, Nanyang Henan (473008), P.R. China
Tel: 0377 63258664 Fax: 0377 63208175 Web www.china-ex.com



Electrical Apparatus for Explosive Atmospheres

CERTIFICATE OF CONFORMITY

Page 4 of 4

3.Rating: 240V, 15A

国家防爆

4.Ingress protection: IP66/67

5.Ex marking: Ex d IIC T6 Gb, Ex d IIB+H $_2$ T6 Gb, Ta=-60 $^{\circ}$ C to +60 $^{\circ}$ C; Ex d IIC T5 Gb, Ex d IIB+H $_2$ T5 Gb, Ta=-60 $^{\circ}$ C to +75 $^{\circ}$ C; Ex d IIC T4 Gb, Ex d IIB+H $_2$ T4 Gb, Ta=-60 $^{\circ}$ C to +110 $^{\circ}$ C; Ex d IIC T3 Gb, Ex d IIB+H $_2$ T3 Gb, Ta=-60 $^{\circ}$ C to +175 $^{\circ}$ C; Ex tD A21 IP66/67 T85 $^{\circ}$ C, Ta = -50 $^{\circ}$ C to +60 $^{\circ}$ C; Ex tD A21 IP66/67 T100 $^{\circ}$ C, Ta = -50 $^{\circ}$ C to +75 $^{\circ}$ C;

6. Specific conditions of safety use:

- 1) The IIC enclosures are excluded from use in carbon disulphide atmospheres.
- 2) The air pressure to the valve block, when fitted, shall not exceed 10.0 bar.

Ex tD A21 IP66/67 T135 °C, Ta = -50 °C to +110 °C

- 3) For ambient temperatures above 110 $^{\circ}$ C, the degrees of ingress protection IP66 and IP67 are not endorsed.
- 4) The slotted hexagonal head cover screws are not of standard form; they shall only be replaced with identical screws sourced from the equipment manufacturer.
- 5) The hexagonal head cover screws are to be replaced only with stainless steel A2-70 or A4-80 screws to GB/T3098.6.
- 6) Cover fasteners are to be tightened to a torque value of 10.85 Nm (8ft/lbs) minimum.
- 7) Before application, certified Ex d IIC Gb, Ex tD A21 IP66/67 cable gland and/or stopping plug must be applied, suitable for the conditions of use and correctly installed.
- 8) Under certain extreme circumstances, the non-metallic parts incorporated in the enclosure of this equipment may generate an ignition capable level of electrostatic charge. Therefore the equipment shall not be installed in a location where the external conditions are conducive to the build-up of electrostatic charge on such surfaces. In addition, the equipment shall only be cleaned with a damp cloth.

Director

77

Date:

Valid until:

12022-03-07

2027-03-06



南阳防爆电气研究所

NANYANG EXPLOSION PROTECTED ELECTRICAL APPARATUS RESEARCH INSTITUTE

国家防爆电气产品质量检验检测中心

CHINA NATIONAL QUALITY SURVEY AND TEST, CENTEN FOR EXPLOSION PROTECTED ELECTRICAL PRODUCTS
Address, No. 20 Gorfb. Zhongjing Rd, Nanyang Hanan A73008), P.R. China
Tel:0371 63258664 Fax:0377 63208175 Web: www.china-ex.com