



Legal representative entity for the
European Union:

Emerson Automation Solutions, Actuation Technologies
Holland Faszor 6, 8000 Székesfehérvár, Hungary

ROC nr. 8440
Rev. 3

FieldQ

EU DECLARATION OF CONFORMITY

Issued in accordance with the
EMC Directive 2014/30/EU, Appendix 1
ATEX Directive 2014/34/EU

We hereby declare, that the products specified below meet the basic health and safety requirements of the above mentioned European Directives.

Product description:	QC54 Foundation Fieldbus Control module
Serial number:	Each Control module has an identifiable serial number
Year of Construction:	Each Control module has an identifiable Year of Construction
Manufacturer:	Emerson Process Management Valve Automation (M) Sdn. Bhd. Lot 13112, Mukim Labu, Kawasan Perindustrian Nilai, 71807 Nilai, Negeri Sembilan Malaysia

EMC Directive 2014/30/EU

Types:	QC54...
Applicable standards:	IEC61326-1 : 2012 NAMUR Recommendations : NE21: 2004

ATEX Directive 2014/34/EU

Types:	QC54...P4...
ATEX Certificate No.:	DEKRA 16ATEX0006 X
Marking:	Ⓢ II 3 G Ex nA IIC T4 Gc Ta = -20°C ... +50°C Ⓢ II 2 D Ex tb IIIC T80°C Db
Applicable standards:	EN 60079-0 : 2012 + A11 : 2013 EN 60079-15 : 2010 EN 60079-31 : 2014

Types:	QC54...P1...
ATEX Certificate No.:	DEKRA 16ATEX0006 X
Marking:	Ⓢ II 1 G Ex ia IIC T4 Ga Ⓢ II 1 D Ex ia IIIC T80°C Da Ta = -20°C ... +50°C
Applicable standards:	EN 60079-0 : 2012 + A11 : 2013 EN 60079-11 : 2012
Notified body:	DEKRA Certification B.V., Notified body no : 0344 Meander 1051, 6825 MJ Arnhem, The Netherlands

Signed:
Name:
Position:


S. Jones
Director, Rack and Pinion SBU
Emerson Automation Solutions
Actuation Technologies

VCCAQ-15292-EN

Date: 2020-04-07
Place: Houston TX, U.S.A.